

Electric Outages Lewes BPW

Month	Date	Circuit	Customers Interrupted	Duration	Cause	Percent System Reliability
January 2019	1/02/19	1	8	20	Squirrel	99.98385%
	1/17/19	1	900	30	Tree	
	1/26/19	4	1	30	Squirrel	
February 2019	2/4/19	1	4	30	Squirrel	99.99992%
March 2019	no outages					100%
April 2019	no outages					100%
May 2019	5/12/19	3	6	60	Wind	99.99855%
	5/16/19	3	6	30	Squirrel	
	5/19/19	3	10	45	Equipment Damage	
	5/20/19	1	2	25	Squirrel	
	5/21/19	4	17	45	Squirrel	
	5/21/19	4	5	30	Snake	
	5/22/19	3	5	30	Squirrel	
	5/24/19	1	4	20	Squirrel	
	5/25/19	1	4	60	Squirrel	
June 2019	6/1/19	4	8	45	Squirrel	99.99675%
	6/6/19	1	1	30	Squirrel	
	6/6/19	4	3	30	Squirrel	
	6/07/19	3	3	60	Bird	
	6/07/19	3	3	120	Bird	
	6/10/19	3	1	60	Equipment Worn out	
	6/22/19	1	1	120	Equipment Damage	
	6/23/19	1	34	120	Squirrel	
July 2019	7/19/19	4	3717	80	Storm	99.82309%
	7/19/19	3	3	4	Equipment Worn out	
August 2019	8/2/19	1	14	150	Equipment Damage	99.98566%
	8/5/19	2	44	90	Equipment Damage	
	8/19/19	1	900	20	Wind	
September 2019	No outages					100%
October 2019	10/20/19	3	26	90	Wind	99.99861%
November 2019	11/21/19	1	3	90	Squirrel	99.9989
December 2019	12/6/19	3	3	60	Equipment Worn out	99.99975
	12/8/19	3	4	60	Squirrel	

TOTAL 2019 reliability = 99.8217%

Unplanned 2019 reliability = 99.8217%